	Document Title: Impact Performance Certification Authorization Report	Doc No: FRM B1-43	
		Rev No: 4	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 190 - 287
Issue Date: 12/23/2014
Revision Date: 10/10/2018
Expiration Date: 11/19/2021
Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	Model: DH5560 PVC Impact Fin/Equal Leg Double Hung Operator Type: H Config: All, GS-5/16" Ann Lami IG Max Width: 52 Max Height: 86 Corresponding Structural CARs: 190-1034.0

Referenced Standard:	Product Rating:
ASTM E1886-05/E1996-12	Missile Level D, Wind Zone 4, DP=+/-50, 52x86

Qualifying Test Information:	
Test Report No:	FTL-7981/7982
Test Report Expiration:	11/19/2021

Authorized Signature:



2018.10.11
13:15:32 -04'00'

Keystone Certifications, Inc.
145 Limekiln Rd., Suite 100B
New Cumberland, Pennsylvania 17070
Phone: 717-932-8500
Fax: 717-932-8501

	Document Title: Impact Performance Certification Authorization Report	Doc No: FRM B1-43	
		Rev No: 4	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 190 - 288
Issue Date: 12/23/2014
Revision Date: 10/10/2018
Expiration Date: 11/19/2021
Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	Model: DH5560 PVC Impact Fin/Equal Leg Double Hung Operator Type: H Config: All, GS-5/16" Ann Lami IG Max Width: 52 Max Height: 86 Corresponding Structural CARs: 190-1035.0

Referenced Standard:	Product Rating:
ASTM E1886-05/E1996-12	Missile Level D, Wind Zone 4, DP=+65/-70, 52x86

Qualifying Test Information:	
Test Report No:	FTL-7983/7984/8159
Test Report Expiration:	11/19/2021

Authorized Signature:



2018.10.11
13:16:01 -04'00'

Keystone Certifications, Inc.
145 Limekiln Rd., Suite 100B
New Cumberland, Pennsylvania 17070
Phone: 717-932-8500
Fax: 717-932-8501

	Document Title: Structural Performance Certification Authorization Report	Doc No: FRM B1-02		
		Rev No: 7	Page: 1	Of: 1
Required By: PRO B1-03				

CAR & Product ID Number: 190 - 1034.0
Issue Date: 12/23/2014
Revision Date: 10/10/2018
Expiration Date: 11/19/2021
Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information: PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	Product Information: Model: DH5560 PVC Impact Equal Leg Double Hung Operator Type: H Config: All, GS-5/16" Ann Lami IG Max Width: 52 Max Height: 86
---	---

Referenced Standard: AAMA/WDMA/CSA 101/I.S.2/A440-11	Product Rating: Class LC-PG50 1324x2192 (52x86)-Type H WTP=9.75
--	---


Qualifying Test Information:	
Test Report No:	FTL-7979
Test Report Expiration:	11/19/2021

Authorized Signature:



2018.10.10
16:28:24 -04'00'

Keystone Certifications, Inc.
145 Limekiln Rd. Suite 100B
New Cumberland, Pennsylvania 17070
Phone: 717-932-8500
Fax: 717-932-8501

	Document Title: Structural Performance Certification Authorization Report	Doc No: FRM B1-02	
		Rev No: 7	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 190 - 1035.0
Issue Date: 12/23/2014
Revision Date: 10/10/2018
Expiration Date: 11/19/2021
Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	Model: DH5560 PVC Impact Equal Leg Double Hung Operator Type: H Config: All, GS-5/16" Ann Lami IG Max Width: 52 Max Height: 86

Referenced Standard:	Product Rating:
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class LC-PG65 1324x2192 (52x86)-Type H Neg DP=70

Qualifying Test Information:	
Test Report No:	FTL-7980
Test Report Expiration:	11/19/2021

Authorized Signature:



2018.10.10
16:29:51 -04'00'

Keystone Certifications, Inc.
145 Limekiln Rd. Suite 100B
New Cumberland, Pennsylvania 17070
Phone: 717-932-8500
Fax: 717-932-8501